

**GOVERNMENT OF TRIPURA  
OFFICE OF THE ASSISTANT ENGINEER  
DRINKING WATER & SANITATION SUB-DIVISION,  
TELIAMURA, KHOWAI TRIPURA.**

No. F.7(117)/AE/DWS/TLM/ 1168

Dated, 12/03/2024.

To

The Principal,  
Assam Rifles High School,  
Teliamura, Khowai, Tripura.

**Sub:** - Submission of chemical test report of water sample.

**Ref No.**0002/ARHS/2024/7198, **Date**,01/03/2024.


Sir,

With reference to the above letter, the chemical test reports of the water sample are sent here with after conduction necessary tests in the DWS Lab-Teliamura.

This is your kind information and necessary action.

**Yours faithfully,**

**Enclo:-** As stated.

  
Assistant Engineer  
D.W.S, Sub-Division  
Teliamura, Khowai.

# **Sub-Divisional Water Testing, Laboratory DWS Sub-Division Teliamura Khowai, Tripura.**

## **\*WATER TESTING REPORT:-**

WATER TESTING REPORT :-										
Sl. No.	Name of School	Date of Collection	Date of Test	Result (mg/l)						Remarks
				Temperature	PH	Turbidity (NTU)	TDS (mg/l)	Hardness (mg/l)	Iron (mg/l)	
1	Assam Rifles High School, Teliamura Khowai Tripura.	01-03-24	06-03-24	26.7°C	7.0	0.4	42	78	0.3	P. Limit PH:-6.5-8.5 Turbidity:-05, Iron:-1.0 mg/l. Calcium- 75-200 mg/l. Magnesium-30-150 mg/l. Hardness-200-600 mg/l.

*[Signature]*  
Sr. Research Assistant,  
DWS Sub-Division Teliamura  
Khowai Tripura.

*[Signature]*  
Assistant Engineer  
DWS Sub-Division Teliamura  
Khowai Tripura.